


NOTES:
 POWER TO TERMINALS ONE & TWO OPENS THE VALVE (CCW ROTATION)
 POWER TO TERMINALS ONE & THREE CLOSSES THE VALVE (CW ROTATION)
 TERMINALS 4 & 5 ARE FOR LIGHT INDICATION

WIRING DIAGRAM ILLUSTRATES THE ACTUATOR IN THE OPEN POSITION

FIELD WIRING



----- OPTIONAL EQUIPMENT
 _____ FIELD WIRING

IC_I Indelac Controls, Inc.

WIRING DIAGRAM FOR STANDARD
 1PH/60Hz/AC ELECTRIC ACTUATOR
 ILLUSTRATING SOME COMMON OPTIONS

JLR 5-19-99
990520

Two Position Actuator