



BATTERY STATUS CAN BE CHECKED WITH THE INCOMING POWER ON BY SHORTING THE 2 BATT TEST POINTS J7-2 & J10-1 MOMENTARILY.

.THE USER IS REQUIRED TO MAKE SURE THAT THE DC POWER GROUND (-) AND THE CONTROL SIGNAL GROUND (-) ARE TIED TOGETHER. AND ALSO REFERENCED TO EARTH GROUND AT THE CONTROL CABINET

	CONTROLS, IN		c Controls, Inc. rence, Ky. 41042	
OF INDELAC CONTROLS INC. ANY REPRODUCTION IN PART OR AS A	WIRING DIAGRAM, SAFE N SECURE 2000, 12VDC, "L" SERIES; WITH TRANSMITTER & 4-20mA POSITIONER, OPTIONAL HEATER & AUXILIARY SWITCHES - SINGLE ENCLOSURE			

WJR	30JUN20	W200630
-----	---------	---------